

# Invitation of quotation for Supply of electrical accessories at Paediatric Emergency at AIIMS Jodhpur.

Inquiry No.

AIIMS/Jodh./E.E. (E)/Q.N./2019/14

Inquiry Issue Date

08 July 2019

Last Date of Submission

15 July 2019 upto 03:00 PM



**All India Institute of Medical Sciences, Jodhpur**

Basni Phase - II, Jodhpur - 342005, Rajasthan

Telefax: 0291- 2012978 [www.aiimsjodhpur.edu.in](http://www.aiimsjodhpur.edu.in)



**ALL INDIA INSTITUTE OF MEDICAL SCIENCES, JODHPUR**  
**अखिल भारतीय आयुर्विज्ञान संस्थान, जोधपुर**

Inquiry No. AIIMS/Jodh. /E.E. (E)/Q.N./2019/14

Dated: 08 July 2019

**QUOTATION NOTICE**


Sealed Quotations are invited from the vendors/supplier/contractor on behalf of the Director, AIIMS Jodhpur for **Supply of electrical accessories at Paediatric Emergency at AIIMS Jodhpur.** On or before **15 July 2019 up to 3:00 PM** and the quotation will be opened on the same day upto 3:30 PM.

**General Terms and Conditions:**

1. The quotations received after 15 July 2019 or unsealed shall not be entertained under any circumstances whatsoever. In case of postal delay, this Institute will not be responsible. The offer Submitted by/through Fax/Email shall not be considered and no correspondence will be entertained in this matter.
2. Quotations must be in the enclosed prescribed duly signed by the Proprietor/Partner/Director or their Authorized Representative, in case of signing of quotation by the authorized representative letter of authorization must be attached with the quotation. Quotation must be dropped in "Quotation Box" located in Administration Block of AIIMS, Jodhpur. Quotation must be in a sealed envelope super scribed with inquiry number.
3. Rates must be quoted in "Indian Rupees" and as per the format specified taxes extra if any must be written separately.
4. Rates must be quoted FOR basis (including Freight charges, Insurance, installation etc.)
5. No overwriting or cutting is permitted in the rate. If found, the quotation shall be summarily rejected.
6. The rates quoted must be valid for 90 days minimum from the date of opening of the quotation.
7. Becoming L1 will not be the criteria for awarding of work unless the rates are reasonable & justified.
8. RTGS/NEFT details need to be furnished by the supplier with the quotation on the Annexure A.
9. The firm/agency may satisfy the following conditions and attach self-attested copy of the same with the quotation:
  - The firm shall have valid GSTIN and IT PAN.
  - The firm should not be black listed by any Govt. Agency/Dept.
10. Quotations qualified by such vague and indefinite expressions such as "subject to prior confirmation", "subject to immediate acceptance" etc. will be treated as vague offers and rejected accordingly. Any conditional quotation shall be rejected summarily.
11. The time allowed for carrying out the above work is 30 days from date of issue of work order.
12. If the supplier/vendor/contractor fails to carry out the above work on or before the stipulated date, then a penalty at the rate of 0.5 % per week of the total order value shall be levied subject to maximum of 10% of the total order value.
13. Payment Terms: Payment will be only after satisfactory completion of work and after inspection by the AIIMS Jodhpur on production GST Invoice.
14. Disputes: In the event of any dispute or disagreement arising between the contractors and any other department of AIIMS Jodhpur with regards to the interpretation of "Terms & Conditions" of this inquiry, the same shall be referred to the Director, AIIMS Jodhpur whose decision will be final and binding upon the contractor.
15. AIIMS, Jodhpur reserves the right to increase or decrease quantity and /or amount of work. Decision of Quantity of work in the AIIMS, Jodhpur will be final in this regard.
16. AIIMS, Jodhpur reserves the right to reject any quotation or part or the whole of inviting quotation process without assigning any reason. Decision of the AIIMS, Jodhpur will be final in this regard.

**Special Terms & Conditions:**

1. Bidder must quote rate in Price Bid Form provided in Annexure A.

  
(Executive Engineer (Electrical))



**ANNEXURE "A"**  
**Price Bid Form**

To,  
The Executive Engineer  
(Electrical), AIIMS, Jodhpur.  
Dear Sir,

1. I/We M/s \_\_\_\_\_ submitting the quotation for Enquiry No **AIIMS/Jodh. /E.E. (E)/Q.N./2019/14** at AIIMS Jodhpur".
2. I/We thoroughly examined, understood and accepted terms & conditions given in the enquiry document, failing which my quotation will be rejected out rightly.
3. I/We hereby offer to supply at the following rates

S. No.	Details of items	Unit	Qty.	Rate	Amount
1	Providing XLPE insulated & P.V.C. sheathed Unarmoured cable of 1.1kV grade with Copper conductor of IS:1554 P-I / IS :7098 as required of size. Make: Finolex / Polycab / RRKabel / Havells.				
a	4core x 10sqmm	mtr.	170.00		
2	Providing XLPE insulated & P.V.C. sheathed Unarmoured cable of 1.1kV grade with Aluminium conductor of IS:1554 P-I / IS :7098 as required of size. Make: Finolex / Polycab / RRKabel / Havells.				
a	3.5core x 35sqmm	mtr.	170.00		
3	Providing following size earth wire in horizontal / vertical run in ground/surface/recess-				
a	6 SWG G.I. ( Hot Dipped ) Wire	mtr.	350.00		
b	Supplying heavy lugs ( Pin type) of following size Make: Metalcraft/ Cabend/ Trinity Touch				
4	10 sqmm (Copper lugs)	each	8.00		
a	35 sqmm (aluminium lugs)	each	8.00		
5	Supplying Recessed/ Surface mounting heavy duty horizontal type prewired sheet steel Distribution board phophatised / powder painted complete with suitable rating insulated copper bus bar, shorting link , neutral link, earth link and din bar,masking sheet, loose wire box, terminal block , duly prewired with suitable size FR PVC insulated copper conductor up to terminal blocks conforming to IS:13032 & IS:8623 including making internal DB terminations with copper lugs , testing etc. as required-				
a	<b>Double door (single phase) 12 Way</b>	each	1.00		
b	<b>Double door (Three phase) 6 Way</b>	each	1.00		
6	Providing 415VAC Four Pole MCB with positive isolation of breaking capacity not less than 10kA (C-tripping characteristic) ISI marked IS 8828(1996)]/ conforming to IEC 60898 in existing board/sheets etc. as required.				
a	40 Amp	each	1.00		
b	63 Amp	each	1.00		
7	Providing double ball bearing capacitor start, aluminium body & blade ceiling fan with down rod up to 30 cm. Make: Almonard/ CG/ Khaitan/ Bajaj/ Usha/ Orient/ Havell's.				
a	1200 mm Sweep	each	4.00		
8	Providing extra down rod of 15 mm dia . ERW (Electrical resistance welded ) of 1.6mm nominal thick medium duty steel pipe including cutting, threading, drilling, fixing quarter pin etc as reqd.	each	4.00		
9	Supplying 20mmX12mm sizes of ISI marked (IS:14927 P-II) PVC casing capping. Make: AKG / BEC / Polycab	r.mtr.	30.00		



