

Invitation of quotation for Supply, Installation, Testing, Commissioning & Validation of Terminal HEPA at Room No. 3 , Kidney Transplant Room , 3rd Floor D&T OT at AIIMS, Jodhpur.

Inquiry No.	AIIMS/Jodh/EE(E)/QN/2023-24/05
Inquiry Issue Date	30-06-2023
Last Date of Submission	08-07-2023



All India Institute of Medical Sciences, Jodhpur
Basni Phase - II, Jodhpur - 342005, Rajasthan
Telefax: 0291- 2012978 www.aiimsjodhpur.edu.in



ALL INDIA INSTITUTE OF MEDICAL SCIENCES, JODHPUR
अखिल भारतीय आयुर्विज्ञान संस्थान, जोधपुर

Inquiry No. AIIMS/Jodh/EE(E)/QN/2023-24/05

Date: 30-06-2023

QUOTATION NOTICE

Sealed Quotations are invited from the authorized contractor/firm on behalf of the Director, AIIMS Jodhpur for **Invitation of quotation for Supply, Installation, Testing, Commissioning & Validation of Terminal HEPA at Room No. 3, Kidney Transplant Room, 3rd Floor D&T OT at AIIMS, Jodhpur.** The last date of submission of quotation is **08-07-2023 up to 3:00 PM.**


General Terms and Conditions:

1. The quotations received after 08-07-2023 or unsealed shall not be entertained under any circumstances whatsoever. In case of postal delay, this Institute will not be responsible. The offer Submitted by/through Fax/Email shall not be considered and no correspondence will be entertained in this matter.
2. Quotations must be in the enclosed prescribed format duly signed by the Proprietor/Partner/Director or their Authorized Representative, in case of signing of quotation by the authorized representative letter of authorization must be attached with the quotation. Quotation must be dropped in "**Quotation Box**" located in Administrative Block of AIIMS, Jodhpur. Quotation must be in a sealed envelope super scribed with inquiry number.
3. **Rates must be quoted in "Indian Rupees"** and the bidder should give rates, showing taxes, levies, if any clearly in the format attached. Quotation not conforming to these requirements shall be rejected and no correspondence will be entertained whatsoever.
4. No overwriting or cutting is permitted in the rate. If found, the quotation shall be summarily rejected.
5. The rates quoted must be valid for 90 days minimum from the date of opening of the quotation.
6. L1 will be decided on composite basis. Becoming L1 will not be the criteria for awarding of work unless the rates are reasonable & justified.
7. RTGS/NEFT details need to be furnished by the supplier mandatorily with the quotation on the Annexure B.
8. Quotations qualified by such vague and indefinite expressions such as "subject to prior confirmation", "subject to immediate acceptance" etc. will be treated as vague offers and rejected accordingly. Any conditional quotation shall be rejected summarily.
9. Contractor shall be fully responsible for any damages caused to govt. property or allottee's property by his or his labour in carrying out the work and shall be rectified by the contractor at his own cost.
10. **Disputes:** In the event of any dispute or disagreement arising between the contractors and any other department of AIIMS Jodhpur with regards to the interpretation of "Terms & Conditions" of this inquiry, the same shall be referred to the Executive Director, AIIMS Jodhpur whose decision will be final and binding. Any disputes are subject to exclusive jurisdiction of competent court and forum in Jodhpur, Rajasthan, India only.
11. The Arbitration shall be held in accordance with the provision of the Arbitration and conciliations Act, 1996 and the venue of arbitration shall be at Jodhpur. The decision of the Arbitrator shall be final and binding on both the parties.
12. AIIMS, Jodhpur reserves the right to increase or decrease quantity and /or amount of work.
13. AIIMS, Jodhpur reserves the right to reject any quotation or part or the whole of inviting quotation process without assigning any reason. Decision of the AIIMS, Jodhpur will be final in this regard.
14. The contract shall be governed by laws and procedures established by Govt. of India, within the framework of applicable legislation and enactment made from time to time concerning such commercial dealings/ processing.
15. Force Majeure: Any delay due to Force Majeure will not be attributable to the AIIMS Jodhpur.
16. Bidder must quote rate in Price Bid Form provided in Annexure B.
17. Detail of AHU installed and other attached for reference. Bidder are requested to visit the site once before submitting the offer.

Annexure A

Scope of Work

1. All materials to be used on this work by the contractor shall be got approved from the Engineer-in- Charge and department has right to inspect the material before installation at site.
2. All damages done to the building, floors, and walls during execution of work shall be the responsibility of the contractor and the same will be made good immediately at his own cost to the satisfaction of the Engineer-in-Charge. Any expenditure incurred by the department in this condition shall be recovered from the contractor and decision of the Engineer-in-Charge about recovery shall be final.
3. The bad workmanship will not be accepted and defects shall be rectified at contractor's cost and of the satisfaction of the Engineer-in-Charge.
4. All the debris of the works should be removed and the site should be cleared by the contractor immediately after the accruing of debris. Similarly any rejected material should be immediately cleared off from the site by the contractor.
5. **The bidder has to undertake the work of supply, installation, testing and commissioning along with the validation of HEPA filter at one go. Validation report shall be submitted after completion of work and before final payment.**
6. The contractor shall make his own arrangement at his own cost for any electrical/general tools required for the work. Whatever consumables and non-consumables required to complete, test commission and validation of HEPA filters will be in scope of agency. Machine tools, plants, aerosol, compressor, tubes, leak detectors etc. will be in scope of agency. Nothing will be provided by Institute.
7. The entire installation shall be at the risk and responsibility of the contractor until these are tested and handed over to the department.
8. All items of interrelated works considered necessary to make the installation complete and operative are deemed to be included shall be provided by the contractor at no extra cost.
9. **The design parameter will have to restore, if there is any deviation in efficiency or design parameter will be intimated initially. Party has to provide drawing if any change has to require for making full functional.**
10. Storage and custody of material will be in scope of Contractor.
11. Site clearance will be in the scope of contractor after completion of work.
12. The Planning, Designing & SITC will be complete in all respect and put in to operation even when certain details have not been given/ left out in the specifications.
13. **FINAL INSPECTION:** - It will be carried out by Engineer-in -Charge. In case any deficiency noticed during demonstration the same will be attended by the Contractor at his own cost & risk.
14. Cutting and Making will be allowed with prior permission, if necessary for completeness for work. Contractor has to repair the damage portion and handover the site as good as before starting the work.
15. All necessary work required to make system fully functional will be taken up by the successful bidder.
16. All validation parameters should be as per ISO 14644.


Executive Engineer (E)
AIIMS, Jodhpur

Annexure B

Price Bid Form

To,
The Executive Engineer (Electrical),
AIIMS, Jodhpur.
Dear Sir,

1. I/We M/s _____ submitting the quotation for Enquiry No. AIIMS/Jodh/EE(E)/QN/2023-24/05 at AIIMS Jodhpur".
2. I/We thoroughly examined, understood and accepted terms & conditions given in the enquiry document, failing which my quotation will be rejected out rightly.
3. I/We hereby offer to supply at the following rates:

S. No.	Details of Items	Qty. (nos.)	Unit	Rate	Amount
1.	Supply, Installation and Validation of HEPA Filter with Housing of following specifications: Filter Size : 450(H)X450(D)X105(D) mm Housing Size : 550(H)X550(D)X175(D) mm Frame: Aluminium Type: Box Type Filter Media : (H-13) Micro Fibre Glass Sealing of media : By means of epoxy Efficiency : 99.999% down to 0.3 μ particle size I.P.D./F.P.D. : \leq 25mm WG/60 mm WG CFM : 450 Separators : Aluminium Housing : GI Powder Coated (Make: - AAF, Aero Bio techniques, Markair)	1	No.		
2.	AHU Modification (Modification of existing AHU from a static of 70mm to minimum 130mm, including redesigning AHU parameters, Air Balancing and associated work)	1	Each		
Total amount exclusive of GST					
GST amount @.....% of above amount					
Total amount inclusive of GST					

✓ **L1 will be decided on composite basis. Becoming L1 will not be the criteria for awarding of work unless the rates are reasonable & justified.**

Date _____
Place _____

Signature of Authorised Person: _____

Name of the Firm/Agency: _____

Phone No: _____

Firm GST No: _____

Bank Account No. :- _____

IFSC Code: _____

Seal:- _____